



SPLIT TYPE  
AIR CONDITIONER  
CEILING TYPE (50Hz)

# SERVICE MANUAL



Indoor unit	Outdoor unit
ABHG30LRTE	AOHG30LETL
ABHG36LRTE	AOHG36LETL

## CONTENTS

SPECIFICATIONS .....	1
DIMENSIONS .....	2
REFRIGERANT SYSTEM DIAGRAM ....	3
CIRCUIT DIAGRAM .....	4
INDOOR PCB CIRCUIT DIAGRAM .....	5
OUTDOOR PCB CIRCUIT DIAGRAM ...	9
ERROR DETECTION .....	14
PARTS (INDOOR UNIT) .....	16
PARTS (OUTDOOR UNIT) .....	21
ACCESSORIES .....	25

# SPECIFICATIONS

## ELECTRICAL DATA

TYPE		Cooling & Heating	
INDOOR UNIT		ABHG30LRTE	ABHG36LRTE
OUTDOOR UNIT		AOHG30LETL	AOHG36LETL
COOLING CAPACITY		8.50 kW	9.40 kW
HEATING CAPACITY		10.0 kW	11.2 kW
POWER SOURCE		230 V, 50 Hz	
RUNNING CURRENT	Cooling	11.6 A	12.8 A
	Heating	12.2 A	13.2 A
INPUT WATTS	Cooling	2.65 kW	2.93 kW
	Heating	2.77 kW	3.02 kW
E.E.R.	Cooling	3.21 kW/kW	3.21 kW/kW
C.O.P.	Heating	3.61 kW/kW	3.71 kW/kW
MOISTURE REMOVAL		2.5 L/hr	3.0 L/hr
AIRCIRCULATION INDOOR		1,660 m3/h	1,900 m3/h
AIRCIRCULATION OUTDOOR	Cooling	3,600 m3/h	3,800 m3/h
	Heating	3,600 m3/h	3,800 m3/h
MAXIMUM CURRENT	Cooling	17.0 A	18.5 A
	Heating	17.0 A	20.0 A

## FAN MOTOR

INDOOR UNIT, Discrimination		MFH-45RV	
INDOOR UNIT	High	1,000 r.p.m.	1,000 r.p.m.
	Medium	910 r.p.m.	910 r.p.m.
	Low	750 r.p.m.	750 r.p.m.
	Quiet	650 r.p.m.	650 r.p.m.
OUTDOOR UNIT, Discrimination		MFE-60TVT	
OUTDOOR UNIT	Cooling	850 r.p.m.	900 r.p.m.
OUTDOOR UNIT	Heating	850 r.p.m.	900 r.p.m.

## NOISE LEVEL

INDOOR UNIT	High	45 dB	47 dB
	Medium	43 dB	43 dB
	Low	37 dB	37 dB
	Quiet	32 dB	32 dB
OUTDOOR UNIT	Cooling	53 dB	54 dB
	Heating	55 dB	55 dB

## COMPRESSOR AND REFRIGERANT

TYPE		Hermetic type, Inverter, 6 poles, DC motor, 2-cylinder rotary
DISCRIMINATION		N-TF30ND1A
WEIGHT (with oil)		15.3 kg
REFRIGERANT TYPE		R410A
PRECHARGED REFRIGERANT		2,100 g
MAX PIPE HEIGHT		30 m
FULL CHARGE	Pipe length 20 m	2,100 g
	30 m	2,500 g
	40 m	2,900 g
	50 m	3,300 g
ADDITIONAL CHARGE		40 g/m

## DIMENSIONS

INDOOR UNIT	H x W x D	240 x 1,660 x 700 mm
OUTDOOR UNIT	H x W x D	830 x 900 x 330 mm


## WEIGHT

INDOOR UNIT	Shipping / Net	58 kg / 46 kg
OUTDOOR UNIT	Shipping / Net	68 kg / 61 kg


DIMENSIONS

(Unit : mm)

INDOOR UNIT



OUTDOOR UNIT




**REFRIGERANT  
SYSTEM DIAGRAM**


Refrigerant direction

—→ : Cool

- - -> : Heat




CIRCUIT DIAGRAM





INDOR PCB  
CIRCUIT DIAGRAM

CONTROL UNIT  
ABHG30LRTE : EZ-0121SHSE  
ABHG36LRTE : EZ-0121THSE



INDOOR UNIT  
MAIN PCB  
ABHG30LRTE : K06AK-120GHSE-C1  
ABHG36LRTE : K06AK-120HHSE-C1









INDOOR UNIT  
INDICATOR PCB  
K04GN-1100HSE-D0


TO MAIN PCB




# OUTDOOR PCB CIRCUIT DIAGRAM

INVERTER ASSEMBLY  
AOHG30LET L : EZ-0121FHUE  
AOHG36LET L : EZ-0121GHUE









# OUTDOOR UNIT TRANSISTOR PCB ( I P M )

AOHG30LETL : K07BT-0901HUE-TR0


AOHG36LETL : K07BT-0900HUE-TR0




OUTDOOR UNIT  
AOHG30LETL  
FILTER PCB  
K05CW-0901HUE-FL0




AOHG36LETL  
FILTER PCB  
K05CW-0900HUE-FL0



OUTDOOR UNIT  
AOHG30LETL  
CAPACITOR PCB  
K05FB-0901HUE-P0



AOHG36LETL  
CAPACITOR PCB  
K05FB-0900HUE-P0



# ERROR DETECTION


## INDOOR UNIT and WIRED REMOTE CONTROL

If you use a wireless remote control, the lamp on the photo detector unit will output error codes by way of blinking patterns.

If you use a wired type remote control, error codes will appear on the remote control display. See the lamp blinking patterns and error codes in the table. An error display is displayed only during running.


### Indoor unit display

Troubleshooting at the display is possible either on the wired or wireless remote control.



### Remote control

This is possible only on a wired remote control. If an error occurs, the following display will be shown. ("Er" will appear in the set room temperature display.)



● : 0.5s on / 0.5s off

◇ : 0.1s on / 0.1s off

( ) : Number of flashing

Indoor unit			Wired remote control	Description
OPERATION lamp (green)	TIMER lamp (orange)	ECONOMY lamp (green)		
● (1)	● (1)	◇	11	Serial communication error
● (1)	● (2)	◇	12	Wired remote control communication error
● (1)	● (5)	◇	15	Check run unfinished
● (2)	● (1)	◇	21	R.C. address or Refrigerant circuit address setting error [Simultaneous Multi]
● (2)	● (2)	◇	22	Indoor unit capacity error
● (2)	● (3)	◇	23	Combination error
● (2)	● (4)	◇	24	• Connection R.C. address error (indoor secondary unit) [Simultaneous Multi] • Connection R.C. address error (indoor unit or branch unit) [Flexible Multi]
● (2)	● (7)	◇	27	Primary unit, secondary unit set-up error [Simultaneous Multi]
● (3)	● (1)	◇	31	Power supply interruption error
● (3)	● (2)	◇	32	Indoor unit PCB model information error
● (3)	● (5)	◇	35	Manual auto switch error
● (4)	● (1)	◇	41	Room temp. sensor error
● (4)	● (2)	◇	42	Indoor unit Heat Ex. Middle temp. sensor error
● (5)	● (1)	◇	51	Indoor unit fan motor error
● (5)	● (3)	◇	53	Drain pump error
● (5)	● (7)	◇	57	Damper error
● (5)	● (15)	◇	5U	Indoor unit error
● (6)	● (2)	◇	62	Outdoor unit main PCB model information error or communication error
● (6)	● (3)	◇	63	Inverter error
● (6)	● (4)	◇	64	Active filter error, PFC circuit error
● (6)	● (5)	◇	65	Trip terminal L error
● (6)	● (10)	◇	6A	Display PCB microcomputers communication error

Indoor unit			Wired remote control	Description
OPERATION lamp (green)	TIMER lamp (orange)	ECONOMY lamp (green)		
● (7)	● (1)	◇	71	Discharge temp. sensor error
● (7)	● (2)	◇	72	Compressor temp. sensor error
● (7)	● (3)	◇	73	Outdoor unit Heat Ex. liquid temp. sensor error
● (7)	● (4)	◇	74	Outdoor temp. sensor error
● (7)	● (5)	◇	75	Suction Gas temp. sensor error
● (7)	● (6)	◇	76	• 2-way valve temp. sensor error • 3-way valve temp. sensor error
● (7)	● (7)	◇	77	Heat sink temp. sensor error
● (8)	● (2)	◇	82	• Sub-cool Heat Ex. gas inlet temp. sensor error • Sub-cool Heat Ex. gas outlet temp. sensor error
● (8)	● (3)	◇	83	Liquid pipe temp. sensor error
● (8)	● (4)	◇	84	Current sensor error
● (8)	● (6)	◇	86	• Discharge pressure sensor error • Suction pressure sensor error • High pressure switch error
● (9)	● (4)	◇	94	Trip detection
● (9)	● (5)	◇	95	Compressor rotor position detection error (permanent stop)
● (9)	● (7)	◇	97	Outdoor unit fan motor 1 error
● (9)	● (8)	◇	98	Outdoor unit fan motor 2 error
● (9)	● (9)	◇	99	4-way valve error
● (9)	● (10)	◇	9A	Coil (expansion valve) error
● (10)	● (1)	◇	A1	Discharge temp. error
● (10)	● (3)	◇	A3	Compressor temp. error
● (10)	● (4)	◇	A4	High pressure error
● (10)	● (5)	◇	A5	Low pressure error
● (13)	● (2)	◇	12	Branch boxes error [Flexible Multi]


## OUTDOOR UNIT

### SPECIAL INSTALLATION SETTING

#### PUMP DOWN (Refrigerant collecting operation)

Perform the following procedures to collect the refrigerant when moving the indoor unit or the outdoor unit.

- (1) Press the push-button switch on the circuit board once.  
The LED on the circuit board starts flashing (one second ON/one second OFF).  
This indicates the start of PUMP DOWN operation.  
When the switch is pressed while the compressor is in operation, PUMP DOWN operation starts automatically.  
When the switch is pressed while the compressor is in stop, the compressor starts to operate automatically, and then move on to PUMP DOWN operation.
- (2) PUMP DOWN operation continues for about 1 minute.  
When PUMP DOWN operation is completed, the compressor stops automatically.  
Then close the 2-way valve and 3-way valve immediately.
- (3) Turn the power off.




**⚠ DANGER**

This part (Choke coil) generates high voltages.  
Never touch this part.




# PARTS

## INDOOR UNIT




Ref.	Description	Part number	
1	Top Cover	9359737018	
2	Intake Grille	9359738015	
3	Air Filter	9359739012	
4	Front Panel	9359734017	
5	Indicator PCB	9705891050	
6	PCB Holder	9359736011	
7	Receiver Cover	9359714002	
8	Badge	9359735175	
9	Decoration Cover R	9359744016	
10	Decoration Cover L	9359745013	
11	Kit (Side Cover R)	9371364025	
12	Kit (Side Cover L)	9371365022	
13	Hanger Bracket	9359742005	

INDOOR UNIT  
Fan motor






Ref.	Description	Part number
21	kit (Separate Wall Sub Assy)	9371366029
22	Fan Motor Assy	9380718017
23	Rubber (Vibration Proof)	9385102002
24	Casing	9359704003
25	Kit (Cover Casing) Sub Assy	9371367019
26	Sirocco Fan Assy	9359701002
27	Joint Assy	9378038011
28	Shaft	9359707004
29	Bearing B Assy	9357921006




INDOOR UNIT  
Evaporator  
Drain pan  
Flap

Ref.	Description	Part number
31	Kit (Base Sub Assy)	9371360010
32	Panel Left Sub Assy	9360427014
33	Kit (Panel Right Assy)	9371361017
34	Evaporator Sub Assy	9360428264
35	Kit (Pipe Cover L)	9371362014
36	kit (Pipe Cover R)	9371363011
37	Drain Pan Sub Assy	9360429032
38	Flap Assy	9359731016
39	Flap Spring	9359730002
40	Sector Gear	9359729006
41	Pinion Gear	9359728009
42	Motor Base	9359727002
43	Step Motor	9900362010
--	Drain Cap	9358746004
--	Pipe Thermistor	9900022020






Ref.	Description	Part number
51	Louver Base Sub Assy	9360432049
52	kit (Louver Base)	9371369013
53	Louver	9359719014
54	Motor Rod	9359723004
55	Louver Rod	9359725008
56	Louver Stopper	9359724001
57	Louver Link	9359726005
58	Louver Spring	9359720003
59	Step Motor H	9900297015
60	Louver Insulation R	9359721000
61	Louver Insulation L	9359722007




INDOOR UNIT  
Control unit



Ref.	Description	Part number
71	Main PCB (30)	9709245255
71	Main PCB (36)	9709245262
72	Power Supply PCB	9707398342
73	Terminal 3P	9703345012
74	Terminal 3P	9306489045
75	Reactor Assy	9707457018
76	Room Thermistor	9703299025
77	Remote Control	9379219037
78	Remote Control Holder	9305642045

# PARTS


## OUTDOOR UNIT




Ref.	Description	Part number	
1	Protective Net	9375381011	
2	Thermo Holder	9375211011	
3	Top Panel Sub Assy	9374417032	
4	Front Panel Sub Assy	9374414079	
5	Service Panel Sub Assy	9374415052	
6	Emblem Rear	9372171059	
7	Right Panel Sub Assy	9374416127	
8	Valve Cover	9374174010	
9	Fan Motor	9379385015	
10	Propeller Fan Assy	9366378020 9366378037	
11	Base Assy	9374166138	
12	Drain Assy	9303029015	
13	Drain Cap	313166024302	




## OUTDOOR UNIT






## OUTDOOR UNIT

Ref.	Description	Part number
41	3-way Valve Assy	9377958013
42	3-way Valve Assy	9377959010
43	Compressor	9810135001
44	Accumulator	9385005006
45	Solenoid	9970055034
46	Expansion Valve Coil	9900057039
47	Wire w/Terminal for comp.	9707837032






















Ref.	Description	Part number	
51	Expansion Valve Assy	9370947144	
52	Condenser A Sub Assy	9374420308	
53	Condenser A Assy	9374433056	
54	Inlet Pipe (Cond) A Assy	9373461067	
55	Outlet Pipe (Cond) A Assy	9374266104	
56	Strainer Assy	9372524015	
57	4-way Valve Assy	9374425198	
58	4-way Valve	9900164010	
59	Check Joint Assy	9372802038	
60	Muffler	9372369050	
61	Pressure Switch	9900186012	

# ACCESSORIES







## INDOOR UNIT

Name and Shape	Q'ty	Application	Part number
Drain hose insulation 	1	Adhesive type 70 x 230	9360464002
VT wire 	1	For fixing the drain hose L 280 mm	313806350303
Coupler heat insulator (large) 	2	For indoor side pipe joint (gas pipe)	9378173569
Coupler heat insulator (small) 	1	For indoor side pipe joint (liquid pipe)	9378173521
Cable tie 	Large 4	For fixing the coupler heat insulator	9301501001
	Small 4		312300787605
Special nut A (large flange) 	4	For installing indoor unit	313005446653
Special nut B (small flange) 	4	For installing indoor unit	313005446759
Installation template 	1	For positioning the indoor unit	9360022004
Auxiliary pipe assembly 	1	For connecting the piping	9374714025
Remote control 	1	For air conditioner operation	9379219037
Remote control holder 	1	For installing remote control on the wall	9305642045
Battery 	2	For remote control	0600185541
Tapping screw 	2	For mounting the remote control holder	0700019036

## OUTDOOR UNIT

Name and Shape	Q'ty	Application	Part number
Drain pipe 	1	For drain piping work	9303029015
Drain cap 	2	For drain piping work	313166024302

## OPTIONAL PARTS

Name and Shape	Model name	Use
<p>Wired remote control</p> 	UTY-RNNYM	Unit control is performed by wired remote control
<p>High functional wired remote control</p> 	UTY-RVNYM	
<p>Simple remote control</p> 	UTY-RSNYM	For air conditioner operation
<p>Drain pump unit</p> 	UTR-DPB24T	
<p>Round flange</p> 	UTD-RF204	To take fresh air
<p>External connect kit</p> 	UTY-XWZX	For control input/output port

