

## Information sheet (Lot.10)

This information includes the results of calculation of the seasonal energy consumption and efficiency for air conditioner in regards to ErP pursuant to the Commission Regulation(EU) No.206/2012 and No.626/2011.

Information to identify the mode(s) to which the information relates to:

AIR CONDITIONER  
 TYPE : MULTI SPLIT  
           WALL MOUNTED  
 Indoor unit(s) : ASHG07KMCE x 5  
 Outdoor unit : AOHG36KBTA5  
 BRAND : GENERAL

N/A = Not Applicable

Function			
Cooling	Yes	Average	Yes
Heating	Yes	Warmer	No
		Colder	No

Design load				Seasonal efficiency			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Cooling	Pdesignc	9.5	kW	Cooling	SEER	8.50	-
Heating/Average	Pdesignh	7.0	kW	Heating/Average	SCOP/A	4.60	-
Heating/Warmer	Pdesignh	N/A	kW	Heating/Warmer	SCOP/W	N/A	-
Heating/Colder	Pdesignh	N/A	kW	Heating/Colder	SCOP/C	N/A	-

Cooling							
Declared capacity for cooling, at indoor temperature 27 (19) °C and outdoor temperature Tj				Declared energy efficiency ratio, at indoor temperature 27 (19) °C and outdoor temperature Tj			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Tj = 35°C	Pdc	9.50	kW	Tj = 35°C	EER d	3.80	-
Tj = 30°C	Pdc	7.00	kW	Tj = 30°C	EER d	5.84	-
Tj = 25°C	Pdc	4.50	kW	Tj = 25°C	EER d	10.31	-
Tj = 20°C	Pdc	2.08	kW	Tj = 20°C	EER d	17.11	-

Heating/Average							
Declared capacity for heating/Average season, at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance/Average season, at indoor temperature 20 °C and outdoor temperature Tj			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Tj = -7°C	Pdh	6.19	kW	Tj = -7°C	COPd	3.01	-
Tj = 2°C	Pdh	3.77	kW	Tj = 2°C	COPd	4.72	-
Tj = 7°C	Pdh	4.06	kW	Tj = 7°C	COPd	6.11	-
Tj = 12°C	Pdh	3.89	kW	Tj = 12°C	COPd	7.71	-
Tj = bivalent temperature	Pdh	6.19	kW	Tj = bivalent temperature	COPd	3.01	-
Tj = operating limit	Pdh	5.35	kW	Tj = operating limit	COPd	2.59	-

Heating/Warmer							
Declared capacity for heating/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Tj = 2°C	Pdh	N/A	kW	Tj = 2°C	COPd	N/A	-
Tj = 7°C	Pdh	N/A	kW	Tj = 7°C	COPd	N/A	-
Tj = 12°C	Pdh	N/A	kW	Tj = 12°C	COPd	N/A	-
Tj = bivalent temperature	Pdh	N/A	kW	Tj = bivalent temperature	COPd	N/A	-
Tj = operating limit	Pdh	N/A	kW	Tj = operating limit	COPd	N/A	-

Heating/Colder							
Declared capacity for heating/Colder season, at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance/Colder season, at indoor temperature 20 °C and outdoor temperature Tj			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Tj = -7°C	Pdh	N/A	kW	Tj = -7°C	COPd	N/A	-
Tj = 2°C	Pdh	N/A	kW	Tj = 2°C	COPd	N/A	-
Tj = 7°C	Pdh	N/A	kW	Tj = 7°C	COP d	N/A	-
Tj = 12°C	Pdh	N/A	kW	Tj = 12°C	COP d	N/A	-
Tj = bivalent temperature	Pdh	N/A	kW	Tj = bivalent temperature	COP d	N/A	-
Tj = operating limit	Pdh	N/A	kW	Tj = operating limit	COP d	N/A	-
Tj=-15°C	Pdh	N/A	kW	Tj = -15°C	COP d	N/A	-

Bivalent temperature				Operating limit temperature			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Heating/Average	T <sub>biv</sub>	-7	°C	Heating/Average	T <sub>ol</sub>	-15	°C
Heating/Warmer	T <sub>biv</sub>	N/A	°C	Heating/Warmer	T <sub>ol</sub>	N/A	°C
Heating/Colder	T <sub>biv</sub>	N/A	°C	Heating/Colder	T <sub>ol</sub>	N/A	°C

Cycling interval capacity				Cycling interval efficiency			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
For cooling	P <sub>cycc</sub>	N/A	kW	For cooling	EER <sub>cycc</sub>	N/A	-
For heating	P <sub>cycc</sub>	N/A	kW	For heating	COP <sub>cycc</sub>	N/A	-
Degradation coefficient cooling	C <sub>dc</sub>	0.25	-	Degradation coefficient heating	C <sub>dh</sub>	0.25	-

Electric power input in power modes other than 'active mode'				Annual electricity consumption			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Off mode (Cooling/Heating)	P <sub>OFF</sub>	5.0/5.0	W	Cooling	Q <sub>CE</sub>	391	kWh/a
Standby mode (Cooling/Heating)	P <sub>SB</sub>	5.0/5.0	W	Heating/Average	Q <sub>HE</sub>	2130	kWh/a
Thermostat-off mode (Cooling/Heating)	P <sub>TO</sub>	11.0/23.0	W	Heating/Warmer	Q <sub>HE</sub>	N/A	kWh/a
Crankcase heater mode (Cooling/Heating)	P <sub>CK</sub>	0.0/0.0	W	Heating/Colder	Q <sub>HE</sub>	N/A	kWh/a

Capacity control			Other items			
Item	Y/N		Item	Symbol	Value	Unit
Fixed	No		Sound power level (Indoor/Outdoor)	L <sub>WA</sub>	54.0/65.0	dB(A)
Staged	No		Global warming potential	GWP	675	kgCO <sub>2</sub> eq.
Variable	Yes		Rated air flow (Indoor/Outdoor)	-	650/2450	m <sup>3</sup> /h

Contact details for obtaining more information	FUJITSU GENERAL LIMITED 3-3-17, Suenaga, Takatsu-ku, Kawasaki, 213-8502, Japan
--	---

V20121214

Information of indoor unit combination

Indoor unit combination (all indoor unit WALL MOUNTED type only)

N/A = Not Applicable

Combination of Indoor unit *1					Cooling				Heating/Average				Heating/Warmer				Heating/Colder			
room1	room2	room3	room4	room5	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class
					Pdesigngc	SEER	Q <sub>CE</sub>	-	Pdesigngh	SCOPIA	Q <sub>HE</sub>	-	Pdesigngh	SCOP/W	Q <sub>HE</sub>	-	Pdesigngh	SCOPI/C	Q <sub>HE</sub>	-
					kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-
07	24	-	-	-	9.0	7.9	399	A++	7.0	4.3	2279	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	22	-	-	-	8.5	7.9	377	A++	6.8	4.3	2214	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	24	-	-	-	9.5	7.8	426	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	22	-	-	-	9.5	7.8	426	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	24	-	-	-	9.5	7.8	426	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	22	-	-	-	9.5	7.8	426	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	24	-	-	-	9.5	7.8	426	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18	18	-	-	-	9.5	7.8	426	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18	22	-	-	-	9.5	7.8	426	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18	24	-	-	-	9.5	7.8	426	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
22	22	-	-	-	9.5	7.8	426	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
22	24	-	-	-	9.5	7.8	426	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
24	24	-	-	-	9.5	7.8	426	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	-	-	8.0	8.2	341	A++	6.5	4.5	2022	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	18	-	-	9.0	8.1	389	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	-	-	8.0	8.2	341	A++	6.5	4.5	2022	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	-	-	8.5	8.1	367	A++	6.8	4.4	2164	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	12	-	-	9.0	8.1	389	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	14	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	14	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	18	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	18	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	18	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	-	-	7.5	8.2	320	A++	6.0	4.5	1867	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	-	-	8.5	8.1	367	A++	6.8	4.4	2164	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	14	-	-	9.0	8.1	389	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	12	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	14	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

\*1  
 07 = 7000Btu/h class = 2.0kW class  
 09 = 9000Btu/h class = 2.5kW class  
 12 = 12000Btu/h class = 3.5kW class  
 14 = 14000Btu/h class = 4.0kW class  
 18 = 18000Btu/h class = 5.0kW class  
 22 = 22000Btu/h class = 6.0kW class  
 24 = 24000Btu/h class = 7.0kW class

Indoor unit combination (all indoor unit WALL MOUNTED type only)

N/A = Not Applicable

Combination of Indoor unit *1					Cooling				Heating/Average				Heating/Warmer				Heating/Colder			
room1	room2	room3	room4	room5	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class
					Pdesigngc	SEER	QCE	-	Pdesigngh	SCOPI/A	QHE	-	Pdesigngh	SCOP/W	QHE	-	Pdesigngh	SCOP/C	QHE	-
					kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-
09	12	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	14	14	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	14	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	14	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	14	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	18	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	18	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	18	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	12	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	14	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	14	14	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	14	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	14	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	14	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	18	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	18	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	18	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	14	14	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	14	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	14	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	14	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	18	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18	18	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	-	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	09	-	8.5	8.4	354	A++	6.8	4.5	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	12	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	22	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	24	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	09	-	9.0	8.4	375	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	12	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	22	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	24	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	12	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

\*1  
 07 = 7000Btu/h class = 2.0kW class  
 09 = 9000Btu/h class = 2.5kW class  
 12 = 12000Btu/h class = 3.5kW class  
 14 = 14000Btu/h class = 4.0kW class  
 18 = 18000Btu/h class = 5.0kW class  
 22 = 22000Btu/h class = 6.0kW class  
 24 = 24000Btu/h class = 7.0kW class

Indoor unit combination (all indoor unit WALL MOUNTED type only)

N/A = Not Applicable

Combination of Indoor unit *1					Cooling				Heating/Average				Heating/Warmer				Heating/Colder			
room1	room2	room3	room4	room5	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class
					Pdesigngc	SEER	Q <sub>CE</sub>		Pdesigngh	SCOP/A	Q <sub>HE</sub>		Pdesigngh	SCOP/W	Q <sub>HE</sub>		Pdesigngh	SCOP/C	Q <sub>HE</sub>	
					kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-
07	07	12	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	22	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	24	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	22	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	24	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	18	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	09	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	12	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	22	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	24	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	12	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	22	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	24	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	22	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	24	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	18	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	12	12	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	12	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	12	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	14	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	14	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	14	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	14	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	09	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	12	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	22	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	24	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	12	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	22	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

\*1

- 07 = 7000Btu/h class = 2.0kW class
- 09 = 9000Btu/h class = 2.5kW class
- 12 = 12000Btu/h class = 3.5kW class
- 14 = 14000Btu/h class = 4.0kW class
- 18 = 18000Btu/h class = 5.0kW class
- 22 = 22000Btu/h class = 6.0kW class
- 24 = 24000Btu/h class = 7.0kW class

Indoor unit combination (all indoor unit WALL MOUNTED type only)

N/A = Not Applicable

Combination of Indoor unit *1					Cooling				Heating/Average				Heating/Warmer				Heating/Colder			
room1	room2	room3	room4	room5	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class
					Pdesignc	SEER	Q <sub>CE</sub>		Pdesignh	SCOP/A	Q <sub>HE</sub>		Pdesignh	SCOP/W	Q <sub>HE</sub>		Pdesignh	SCOP/C	Q <sub>HE</sub>	
					kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-
09	09	12	24	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	14	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	14	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	18	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	12	12	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	12	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	12	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	14	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	14	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	14	14	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	12	12	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	12	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	12	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	14	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	14	14	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	07	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	09	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	18	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	22	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	24	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	09	09	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	09	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	09	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	09	18	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	09	22	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	09	24	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	12	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	12	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	12	18	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	14	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	14	18	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	09	09	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	09	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	09	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	09	18	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	12	22	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	12	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	12	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	12	18	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	14	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

\*1  
 07 = 7000Btu/h class = 2.0kW class  
 09 = 9000Btu/h class = 2.5kW class  
 12 = 12000Btu/h class = 3.5kW class  
 14 = 14000Btu/h class = 4.0kW class  
 18 = 18000Btu/h class = 5.0kW class  
 22 = 22000Btu/h class = 6.0kW class  
 24 = 24000Btu/h class = 7.0kW class

Indoor unit combination (all indoor unit WALL MOUNTED type only)

N/A = Not Applicable

Combination of Indoor unit *1					Cooling				Heating/Average				Heating/Warmer				Heating/Colder				
room1	room2	room3	room4	room5	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	
					Pdesignc	SEER	Q <sub>CE</sub>	Pdesignh	SCOPI/A	Q <sub>HE</sub>	Pdesignh	SCOP/W	Q <sub>HE</sub>	Pdesignh	SCOP/C	Q <sub>HE</sub>					
					kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-	
07	07	12	12	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	12	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	14	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	09	09	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	09	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	09	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	09	18	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	12	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	12	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	14	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	12	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	12	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	09	09	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	09	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	09	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	09	18	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	12	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	12	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	12	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

\*1

- 07 = 7000Btu/h class = 2.0kW class
- 09 = 9000Btu/h class = 2.5kW class
- 12 = 12000Btu/h class = 3.5kW class
- 14 = 14000Btu/h class = 4.0kW class
- 18 = 18000Btu/h class = 5.0kW class
- 22 = 22000Btu/h class = 6.0kW class
- 24 = 24000Btu/h class = 7.0kW class

Indoor unit combination (except all indoor unit WALL MOUNTED type)

N/A = Not Applicable

Combination of Indoor unit *1					Cooling				Heating/Average				Heating/Warmer				Heating/Colder			
room1	room2	room3	room4	room5	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class
					Pdesignc kW	SEER	Q <sub>CE</sub> kWh/a	-	Pdesignh kW	SCOPI/A	Q <sub>HE</sub> kWh/a	-	Pdesignh kW	SCOP/W	Q <sub>HE</sub> kWh/a	-	Pdesignh kW	SCOP/C	Q <sub>HE</sub> kWh/a	-
07	24	-	-	-	9.0	6.0	525	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	22	-	-	-	8.5	6.0	496	A+	6.8	4.0	2380	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	24	-	-	-	9.5	6.0	554	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	22	-	-	-	9.5	6.0	554	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	24	-	-	-	9.5	6.0	554	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	22	-	-	-	9.5	6.0	554	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	24	-	-	-	9.5	6.0	554	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18	18	-	-	-	9.5	6.0	554	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18	22	-	-	-	9.5	6.0	554	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18	24	-	-	-	9.5	6.0	554	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
22	22	-	-	-	9.5	6.0	554	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
22	24	-	-	-	9.5	6.0	554	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
24	24	-	-	-	9.5	6.0	554	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	-	-	8.0	6.3	444	A++	6.5	4.2	2167	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	18	-	-	9.0	6.2	508	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	-	-	8.0	6.3	444	A++	6.5	4.2	2167	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	-	-	8.5	6.2	480	A++	6.8	4.1	2322	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	18	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	12	-	-	9.0	6.2	508	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	14	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	18	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	14	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	18	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	18	18	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	18	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	18	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	-	-	7.5	6.3	417	A++	6.0	4.2	2000	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	-	-	8.5	6.2	480	A++	6.8	4.1	2322	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	14	-	-	9.0	6.2	508	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	18	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	12	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	14	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

\*1

- 07 = 7000Btu/h class = 2.0kW class
- 09 = 9000Btu/h class = 2.5kW class
- 12 = 12000Btu/h class = 3.5kW class
- 14 = 14000Btu/h class = 4.0kW class
- 18 = 18000Btu/h class = 5.0kW class
- 22 = 22000Btu/h class = 6.0kW class
- 24 = 24000Btu/h class = 7.0kW class



Indoor unit combination (except all indoor unit WALL MOUNTED type)

N/A = Not Applicable

Combination of Indoor unit *1					Cooling				Heating/Average				Heating/Warmer				Heating/Colder			
room1	room2	room3	room4	room5	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class
					Pdesignc	SEER	Q <sub>CE</sub>	-	Pdesignh	SCOPI/A	Q <sub>HE</sub>	-	Pdesignh	SCOP/W	Q <sub>HE</sub>	-	Pdesignh	SCOP/C	Q <sub>HE</sub>	-
					kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-
09	12	18	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	14	14	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	14	18	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	14	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	14	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	18	18	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	18	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	18	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	12	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	14	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	18	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	14	14	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	14	18	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	14	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	14	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	18	18	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	18	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	18	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	14	14	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	14	18	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	14	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	14	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	18	18	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18	18	18	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	-	8.0	6.5	431	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	09	-	8.5	6.4	465	A++	6.8	4.2	2267	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	12	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	22	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	24	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	09	-	9.0	6.4	492	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	12	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	22	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	24	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	12	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

\*1

- 07 = 7000Btu/h class = 2.0kW class
- 09 = 9000Btu/h class = 2.5kW class
- 12 = 12000Btu/h class = 3.5kW class
- 14 = 14000Btu/h class = 4.0kW class
- 18 = 18000Btu/h class = 5.0kW class
- 22 = 22000Btu/h class = 6.0kW class
- 24 = 24000Btu/h class = 7.0kW class

Indoor unit combination (except all indoor unit WALL MOUNTED type)

N/A = Not Applicable

Combination of Indoor unit *1					Cooling				Heating/Average				Heating/Warmer				Heating/Colder			
room1	room2	room3	room4	room5	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class
					Pdesigngc	SEER	Q <sub>CE</sub>		Pdesigngh	SCOPI/A	Q <sub>HE</sub>		Pdesigngh	SCOP/W	Q <sub>HE</sub>		Pdesigngh	SCOP/C	Q <sub>HE</sub>	
					kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-
07	07	12	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	22	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	24	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	22	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	24	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	18	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	09	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	12	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	22	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	24	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	12	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	22	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	24	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	22	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	24	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	18	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	12	12	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	12	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	12	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	14	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	14	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	14	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	09	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	12	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	22	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	24	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	12	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	22	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

\*1  
 07 = 7000Btu/h class = 2.0kW class  
 09 = 9000Btu/h class = 2.5kW class  
 12 = 12000Btu/h class = 3.5kW class  
 14 = 14000Btu/h class = 4.0kW class  
 18 = 18000Btu/h class = 5.0kW class  
 22 = 22000Btu/h class = 6.0kW class  
 24 = 24000Btu/h class = 7.0kW class

Indoor unit combination (except all indoor unit WALL MOUNTED type)

N/A = Not Applicable

Combination of Indoor unit *1					Cooling				Heating/Average				Heating/Warmer				Heating/Colder			
room1	room2	room3	room4	room5	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class
					Pdesigngc	SEER	Q <sub>CE</sub>		Pdesigngh	SCOPI/A	Q <sub>HE</sub>		Pdesigngh	SCOP/W	Q <sub>HE</sub>		Pdesigngh	SCOP/C	Q <sub>HE</sub>	
					kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-
09	09	12	24	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	14	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	14	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	18	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	12	12	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	12	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	12	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	14	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	14	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	14	14	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	12	12	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	12	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	12	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	14	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	14	14	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	07	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	09	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	18	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	22 *2	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	24	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	09	09	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	09	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	09	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	09	18	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	09	22 *2	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	09	24	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	12	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	12	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	12	18	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	14	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	14	18	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	09	09	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	09	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	09	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	09	18	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	09	22 *2	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	12	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	12	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	12	18	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	14	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

\*1

07 = 7000Btu/h class = 2.0kW class  
 09 = 9000Btu/h class = 2.5kW class  
 12 = 12000Btu/h class = 3.5kW class  
 14 = 14000Btu/h class = 4.0kW class  
 18 = 18000Btu/h class = 5.0kW class  
 22 = 22000Btu/h class = 6.0kW class  
 24 = 24000Btu/h class = 7.0kW class

\*2

As for the 22 model, WALL MOUNTED type indoor unit is only connectable.

Indoor unit combination (except all indoor unit WALL MOUNTED type)

N/A = Not Applicable

Combination of Indoor unit *1					Cooling				Heating/Average				Heating/Warmer				Heating/Colder			
room1	room2	room3	room4	room5	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class
					Pdesignc	SEER	Q <sub>CE</sub>		Pdesignh	SCOP/A	Q <sub>HE</sub>		Pdesignh	SCOP/W	Q <sub>HE</sub>		Pdesignh	SCOP/C	Q <sub>HE</sub>	
					kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-
07	07	12	12	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	12	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	14	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	09	09	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	09	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	09	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	09	18	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	12	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	12	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	14	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	12	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	12	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	09	09	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	09	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	09	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	09	18	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	12	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	12	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	12	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

\*1

- 07 = 7000Btu/h class = 2.0kW class
- 09 = 9000Btu/h class = 2.5kW class
- 12 = 12000Btu/h class = 3.5kW class
- 14 = 14000Btu/h class = 4.0kW class
- 18 = 18000Btu/h class = 5.0kW class
- 22 = 22000Btu/h class = 6.0kW class
- 24 = 24000Btu/h class = 7.0kW class

Information of unit specification

Model Type	Model No.	Capacity Class	Dimension [H x W x D]	Sound power level(Cooling)	Sound power level(Heating)		
		kW	mm	dB(A)	dB(A)		
OUTDOOR	AOHG36KBT A5	-	884 x 820 x 315	65	68		
WALL MOUNTED	ASHG07KMCC ASHG07KMCE ASHG07KMCF	2.0	270 x 834 x 215	54	56		
	ASHG09KMCC ASHG09KMCE ASHG09KMCF	2.5		55	57		
	ASHG12KMCC ASHG12KMCE ASHG12KMCF	3.5		55	58		
	ASHG14KMCC ASHG14KMCE ASHG14KMCF	4.0		57	59		
	ASHG07KGTB ASHG07KGTE ASHG07KGT F	2.0		270 x 834 x 215	54	56	
	ASHG09KGTB ASHG09KGTE ASHG09KGT F	2.5	55		57		
	ASHG12KGTB ASHG12KGTE ASHG12KGT F	3.5	56		58		
	ASHG14KGTB ASHG14KGTE ASHG14KGT F	4.0	57		59		
	ASHG07KMTB ASHG09KMTB ASHG12KMTB ASHG14KMTB	2.0 2.5 3.5 4.0	270 x 834 x 215		54 55 55 57	56 57 58 59	
	ASHG18KMTB ASHG18KMTE ASHG22KMTB ASHG22KMTE ASHG24KMTB ASHG24KMTE	5.0 6.0 7.0		280 x 980 x 240	60 62 65	61 62 65	
	ASHG07KETA ASHG07KETE ASHG07KET F	2.0			295 x 950 x 230	54	56
	ASHG09KETA ASHG09KETE ASHG09KET F	2.5				55	57
	ASHG12KETA ASHG12KETE ASHG12KET F	3.5	55			58	
	ASHG14KETA ASHG14KETE ASHG14KET F	4.0	57			59	
	ASHG07KETA-B ASHG07KETE-B ASHG07KET F-B	2.0	295 x 950 x 230			54	56
	ASHG09KETA-B ASHG09KETE-B ASHG09KET F-B	2.5		55		57	
	ASHG12KETA-B ASHG12KETE-B ASHG12KET F-B	3.5		55		58	
	ASHG14KETA-B ASHG14KETE-B ASHG14KET F-B	4.0		57		59	
	AUXG07KVLA AUXG09KVLA AUXG12KVLA AUXG14KVLA AUXG18KVLA AUXG22KVLA	2.0 2.5 3.5 4.0 5.0 6.0		245 x 570 x 570 (Panel: 49 x 620 x 620)	46 46 49 50 50 56	47 47 49 55 55 57	
	ARXG07KSLAP ARXG09KSLAP ARXG12KSLAP ARXG14KSLAP ARXG18KSLAP ARXG07KLLAP ARXG09KLLAP ARXG12KLLAP ARXG14KLLAP ARXG18KLLAP ARXG22KMLB ARXH22KMTAP	2.0 2.5 3.5 4.0 5.0 2.0 2.5 3.5 4.0 5.0 6.0 6.0	198 x 700 x 450		52 54 55 60	53 56 57 62	
	ARXG18KLLAP ARXG07KLLAP ARXG09KLLAP ARXG12KLLAP ARXG14KLLAP	5.0 2.0 2.5 3.5 4.0			198 x 900 x 450	58 57 57 58 60	59 57 57 58 60
	ARXG18KLLAP ARXG22KMLB ARXH22KMTAP	5.0 6.0 6.0				58 60 58	58 62 58
	AGHG09KVCA AGHG12KVCA AGHG14KVCA	2.5 3.5 4.0				600 x 740 x 200	52 55 56
	ABHG18KRTA ABHG22KRTA	5.0 6.0	235 x 1080 x 705				53 57