

## EC EFFICIENCY EXAMINATION CERTIFICATE

### Annex III Module B directive 92/42/EEC



<i>Certificate number</i>	: EG 1143/5137 Rev.2	<i>Date of issue</i>	: 3/05/2004
<i>ID number</i>	: 0461AR0148	<i>Revised:</i>	: 13/10/2006
<i>Fabricant</i>	: YGNIS A.G.		
<i>Manufacturer</i>	Wohlhuserstraße 31-33		
<i>Fabrikant</i>	CH - 6017 Ruswil , Luzern		
<i>Commerc.</i>	: YGNIS INT.		
<i>Marketed</i>	Avenue Général Leclerc		
<i>Gecommerc.</i>	F - 92340 Bourg la Reine		
<i>Marque commerc.</i>	: YGNIS		
<i>Trade mark</i>			
<i>Handelsmerk</i>			
<i>Type</i>	: LR / LRK / LR-NT / LRK-NT 21 - 22 - 23 - 24 - 25 - 26 - 27 -		
<i>Model</i>	28 - 29 - 30 - 31 - 32		
<i>Type</i>	LRR / LRRK 47 - 48 - 49 - 50 - 51 - 52 - 53 - 54 - 55		
<i>Genre d'appareil</i>	: HEATING BODY (TO BE EQUIPED WITH FDB)		
<i>Kind of product</i>			
<i>Soort toestel</i>			
<i>Type d'appareil</i>	: B23		
<i>Appliance type</i>			
<i>Type toestel</i>			

The gas-fired heating boilers may be fitted with any forced draught burner which is CE-marked following the EN 676, if the operating characteristics of the boilers related to the rated heat input and the back-pressure in the combustion chamber are situated within the burner's working range.

This document cancels and replaces the previous one of : 20/10/2005

DIRECTOR  
K. DE WIT