

PRODUCT PERFORMANCE RATING

Document ID 1663683853-fb-b350aa56

Issued on: 20 September 2022 - Délivré le : 20 septembre 2022

This product is certified by Eurovent Certita Certification as mentioned on:

Ce produit est certifié par Eurovent Certita Certification comme mentionné sur :



Certificate N° 21.03.105

This document is valid at the date of issue - Check the current validity on www.eurovent-certification.com

Ce document est valide à la date d'édition - Vérifiez la date de validité sur www.eurovent-certification.com

Certification programmes / Programmes de certification

Climatiseurs (Pompes à chaleur Air-Air)

Product type / Type de produit

Air/air, split, réversible (≤ 12 kW)

Model name / Nom du modèle

NISEKO MURALE IM20-NS / E1U20L-NS

Range / Gamme

NISEKO MURALE

Participant / Titulaire

Thermor

Brand / Marque

THERMOR

This performance certificate is delivered for the following project

Project Name

Nom du projet

NISEKO MURALE 2000W

PRODUCT PERFORMANCE RATING

Document ID 1663683853-fb-b350aa56

Issued on: 20 September 2022 - Délivré le : 20 septembre 2022

This product is certified by Eurovent Certita Certification as mentioned on:

Ce produit est certifié par Eurovent Certita Certification comme mentionné sur :



Certificate N° 21.03.105

This document is valid at the date of issue - Check the current validity on www.eurovent-certification.com

Ce document est valide à la date d'édition - Vérifiez la date de validité sur www.eurovent-certification.com

FEATURE	VALUE	UNIT
Seasonal Efficiency In Cooling		
Pdesignc (Design Load Cooling)	2.6	kW
SEER (Seasonal Energy Efficiency Ratio)	6.1	
Qce (Annual electricity consumption for cooling)	149	kWh/annum
SEER Class (Seasonal Energy Efficiency Ratio Class)	A++	
Heating Average Climate		
Pdesignh (Design load heating)	2.4	kW
SCOP (Reference SCOP)	4	
SCOP Class (Seasonal Coefficient Of Performance Class)	A+	
Qhe (Annual electricity consumption for heating)	840	kWh/annum
Acoustic		
LwO env (A-weighted sound level outdoor near the envelope for non ducted units)	62	dB(A)
Lwl1 env (A-weighted sound power level indoor unit 1 (non ducted))	54	dB(A)
Standard Cooling/Cooling PL Cond A		
Pc (Total Cooling Capacity)	2.6	kW
Pec (Effective Power Input for Cooling (for chilled water cooled Close Control units only)	0.8	kW
EER (Energy Efficiency Ratio)	3.23	
Cooling PL CondB		
Pc @ 30°C (Declared Cooling Capacity @ 30°C)	1.92	kW
EER @ 30°C (Declared Energy Efficiency @ 30°C)	4.9	
Cooling PL CondC		
Pc @ 25°C (Declared Cooling Capacity @ 25°C)	1.23	kW
EER @ 25°C (Declared Energy Efficiency @ 25°C)	7.4	
Cooling PL CondD		
Pc @ 20°C (Declared Cooling Capacity @ 20°C)	0.8	kW
EER @ 20°C (Declared Energy Efficiency @ 20°C)	9.7	
Standard Heating		
Ph (Heating Capacity)	2.8	kW
Peh (Net Electric Power Consumption for Heating Only application)	0.75	kW
COP (Coefficient Of Performance)	3.71	



Certificate N° 21.03.105

This document is valid at the date of issue - Check the current validity on www.eurovent-certification.com

Ce document est valide à la date d'édition - Vérifiez la date de validité sur www.eurovent-certification.com

Heating PL CondA		
Ph @ -7°C (Declared Heating Capacity @ -7°C)	2.12	kW
COP @ -7°C (Declared Coefficient Of Performances @ -7°C)	2.67	
Heating PL CondB		
Ph @ +2°C (Declared Heating Capacity @ +2°C)	1.29	kW
COP @ 2°C (Declared Coefficient Of Performances @ 2°C)	4.1	
Heating PL CondC		
Ph @ +7°C (Declared Heating Capacity @ +7°C)	0.92	kW
COP @ +7°C (Declared Coefficient Of Performances @ +7°C)	4.85	
Heating PL CondD		
Ph @ +12°C (Declared Heating Capacity @ +12°C)	0.8	kW
COP @ +12°C (Declared Coefficient Of Performances @ +12°C)	5.9	
Bivalent Point		
Tbiv (Bivalent Temperature)	-7	°C
COP @ Tbiv (Declared coefficient of performances at bivalent temperature condition)	2.67	
Ph TBiv (Heating capacity at bivalent temperature)	2.12	kW
TOL Runing Test		
TOL (Operating LimitTemperature)	-10	°C
Ph E (Declared Heating Capacity @ TOL)	1.92	kW
COP E (Declared Coefficient Of Performances @ TOL)	2.49	
Heating Warmer Climate		
SCOP (Refrence SCOP Warmer Climate)	5.1	
SCOP Class warmer climate (Seasonal Coefficient Of Performance Class (warmer climate))	A+++	
Qhe (Annual Electricity consumption)	549	kWh/annum
Poffc		
Poff (Power consumption in off mode)	2	W
Psb		
Psb (Power consumption in standby mode cooling (Paux, cooling))	2	W
Ptoc		
Pto (Power consumption in thermostat off mode)	10	W
General		

PRODUCT PERFORMANCE RATING

Document ID 1663683853-fb-b350aa56

Issued on: 20 September 2022 - Délivré le : 20 septembre 2022

This product is certified by Eurovent Certita Certification as mentioned on:

Ce produit est certifié par Eurovent Certita Certification comme mentionné sur :



Certificate N° 21.03.105

This document is valid at the date of issue - Check the current validity on www.eurovent-certification.com

Ce document est valide à la date d'édition - Vérifiez la date de validité sur www.eurovent-certification.com

FEATURE	VALUE	UNIT
General		
Inverter (Inverter (True/False))	true	
Capacity Control	Variable	
Main Power Supply (Voltage (V) - Phase - Frequency (Hz))	230-1-50	
Refrigerant	R32	
Refr. Line (Refrigerant Line. If possible)	5m	m
Mounting (Mounting Type)	Wall mounted	
Eligible CEE		
Eligible CEE (this item provide information if the unit is eligible to the certificat d'economie d'energie)	true	

Air Conditioners / Climatiseurs
/ Comfort Air Conditioners below 12kW
/ Climatiseurs de moins de 12kW

Granted on March 31, 2021 – Date 1ère admission 31 mars 2021

This document is valid at the date of issue – Check the current validity on:
Document valable à la date d'émission – Vérifier la validité en cours sur :
www.eurovent-certification.com

Participant/Titulaire

Thermor
ZA Charles Beauhaire – 17 rue Croix Fauchet – BP46
45141 Saint Jean de la ruelle, France

This product performance certificate is issued by Eurovent Certita Certification according to the certification rules:

ECP AC – « Air Conditioners » in force at established date.

Pursuant to the decision notified by Eurovent Certita Certification, the right to use the mark ECP shall be granted to the beneficiary company for all products inside the defined scope according to “certify-all” principle and in the conditions defined by the certification program mentioned.

Unless withdrawn or suspended, this certificate remains valid as long as the requirements for the certification program framework are met. The validity of the certificate is to be verified on www.eurovent-certification.com

THIS CERTIFICATE HAS BEEN ISSUED ON 12/10/2021
THIS CERTIFICATE IS VALID UNTIL 31/10/2022

Ce certificat de performance produit est délivré par Eurovent Certita Certification dans les conditions fixées par le référentiel :

ECP AC – « Climatiseurs » en vigueur à date d'édition.

En vertu de la décision notifiée par Eurovent Certita Certification, le droit d'usage de la marque ECP, est accordé à la société qui en est bénéficiaire pour les tous les produits entrant dans le champ d'application défini selon le principe “certify-all” et dans les conditions définies par le programme de certification mentionné.

Sauf retrait ou suspension, ce certificat demeure valide tant que les conditions du référentiel du programme de certification sont respectées. La validité du certificat est à vérifier sur le site Internet www.eurovent-certification.com

CE CERTIFICAT A ÉTÉ EMIS LE 12/10/2021
CE CERTIFICAT EST VALIDE JUSQU'AU 31/10/2022

Paris, 12 octobre 2021

MANAGING BOARD MEMBER / MEMBRE DIRECTOIRE



Organisme accrédité n° 5-0517 Certification
Produits et Services selon la norme NF EN
ISO/CEI 17065:2012
Portée disponible sur www.cofrac.fr

Accreditation #5-0517 Products and Services
Certification according to NF EN ISO/CEI
17065:2012 –
Scope available on www.cofrac.fr

COFRAC est signataire des accords MLA d'EA
et MLA d'IAF,
COFRAC is signatory of EA MLA and IAF MLA,
list of EA members is available on
www.european-accreditation.org/ea-members
list of IAF members is available on
www.iaf.nu/articles/IAF_MEMBERS_SIGNATORIES/4



Appendix / Annexe

Granted on March 31, 2021 – *Date 1ère admission 31 mars 2021*

This document is valid at the date of issue – Check the current validity on:

Document valable à la date d'émission – Vérifier la validité en cours sur :

www.eurovent-certification.com

List of certified products and characteristics is displayed on:

La liste des références et caractéristiques certifiées est disponible sur le site :

www.eurovent-certification.com

This product performance certificate is valid for the following trade names:

Ce certificat de performance produit est valide pour les marques commerciales suivantes:

Trade Name / Marque Commerciale

THERMOR

This product performance certificate is valid for the following manufacturing places:

Ce certificat de performance produit est valide pour les sites de production suivants:

Manufacturing Place / Site de Production

Not applicable for this certification programme / Non applicable pour ce programme de certification

This product performance certificate is valid for the following software:

Ce certificat de performance produit est valide pour les logiciels de sélection suivants:

Software / Logiciel de sélection

Not applicable for this certification programme / Non applicable pour ce programme de certification