

**CERTIFICAT D'EXAMEN CE DE RENDEMENT**  
**EC EFFICIENCY EXAMINATION CERTIFICATE**  
**EG-RENDEMENTSONDERZOEK CERTIFICAAT**  
**EG-WIRKUNGSGRADPRÜFBESCHEINIGUNG**

Annexe III Module B de la directive 92/42/CEE

**Annex III Module B directive 92/42/EEC**

Bijlage III Module B richtlijn 92/42/EEG

Anhang III Modul B Richtlinie 92/42/EWG



<i>Certificate number</i>	<i>EG1145/5136</i>	<i>Date of issue : 3/05/2004</i>
<i>ID number</i>	<i>: 0461AT0324</i>	
<i>Fabricant</i>	<i>: YGNIS INDUSTRIE</i>	
<i>Manufacturer</i>	<i>Route de Solesmes</i>	
<i>Fabrikant</i>	<i>FR - 59400 CAUROIR</i>	
<i>Commerc.</i>	<i>: YGNIS A.G.</i>	
<i>Marketed</i>	<i>Wohlhuserstraße 31-33</i>	
<i>Gecommerc.</i>	<i>CH - 6017 Ruswil , Luzern</i>	
<i>Marque commerc.</i>	<i>: YGNIS</i>	
<i>Trade mark</i>		
<i>Handelsmerk</i>		
<i>Type</i>	<i>: LRP / LRP-NT 1 - 2 - 3 - 4 - 5 - 6 - 7 - 8 - 9 - 10 - 11 - 12 - 13 - 14</i>	
<i>Model</i>		
<i>Type</i>		
<i>Genre d'appareil</i>	<i>: HEATING BODY (TO BE EQUIPPED WITH FDB)</i>	
<i>Kind of product</i>		
<i>Soort toestel</i>		
<i>Type d'appareil</i>	<i>: B23</i>	
<i>Appliance type</i>		
<i>Type toestel</i>		

The gas-fired heating boilers may be fitted with any forced draught burner which is CE-marked following the EN 676, if the operating characteristics of the boilers related to the rated heat input and the back-pressure in the combustion chamber are situated within the burner's working range.

DIRECTOR  
K. DE WIT

TGP-08-15  
2002-04-12