

# PRODUCT PERFORMANCE RATING

Document ID 1662723918-5a-6ffe879d

Issued on: 9 September 2022 - Délivré le : 9 septembre 2022

This product is certified by Eurovent Certita Certification as mentioned on:

Ce produit est certifié par Eurovent Certita Certification comme mentionné sur :



## Certificate N° 21.03.105

This document is valid at the date of issue - Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)

Ce document est valide à la date d'édition - Vérifiez la date de validité sur [www.eurovent-certification.com](http://www.eurovent-certification.com)

Certification programmes / Programmes de certification

Climatiseurs (Pompes à chaleur Air-Air)

Product type / Type de produit

Air/air, split, réversible ( $\leq 12$  kW)

Model name / Nom du modèle

NAGANO MURALE PURE IM26V2-NG / E1U26LV2-NG

Range / Gamme

NAGANO MURALE PURE

Participant / Titulaire

Thermor

Brand / Marque

THERMOR

This performance certificate is delivered for the following project

**Project Name**

*Nom du projet*

NAGANO murale Pure 2600W

# PRODUCT PERFORMANCE RATING

Document ID 1662723918-5a-6ffe879d

Issued on: 9 September 2022 - Délivré le : 9 septembre 2022

This product is certified by Eurovent Certita Certification as mentioned on:

Ce produit est certifié par Eurovent Certita Certification comme mentionné sur :



## Certificate N° 21.03.105

This document is valid at the date of issue - Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)

Ce document est valide à la date d'édition - Vérifiez la date de validité sur [www.eurovent-certification.com](http://www.eurovent-certification.com)

| FEATURE                                                                                    | VALUE | UNIT      |
|--------------------------------------------------------------------------------------------|-------|-----------|
| <b>Seasonal Efficiency In Cooling</b>                                                      |       |           |
| Pdesignc (Design Load Cooling)                                                             | 2.6   | kW        |
| SEER (Seasonal Energy Efficiency Ratio)                                                    | 8.5   |           |
| Qce (Annual electricity consumption for cooling)                                           | 107   | kWh/annum |
| SEER Class (Seasonal Energy Efficiency Ratio Class)                                        | A+++  |           |
| <b>Heating Average Climate</b>                                                             |       |           |
| Pdesignh (Design load heating )                                                            | 2.4   | kW        |
| SCOP (Reference SCOP)                                                                      | 4.6   |           |
| SCOP Class (Seasonal Coefficient Of Performance Class)                                     | A++   |           |
| Qhe (Annual electricity consumption for heating)                                           | 731   | kWh/annum |
| <b>Acoustic</b>                                                                            |       |           |
| LwO env (A-weighted sound level outdoor near the envelope for non ducted units )           | 59    | dB(A)     |
| Lwl1 env (A-weighted sound power level indoor unit 1 (non ducted))                         | 53    | dB(A)     |
| <b>Standard Cooling/Cooling PL Cond A</b>                                                  |       |           |
| Pc (Total Cooling Capacity)                                                                | 2.6   | kW        |
| Pec (Effective Power Input for Cooling (for chilled water cooled Close Control units only) | 0.65  | kW        |
| EER (Energy Efficiency Ratio)                                                              | 4     |           |
| <b>Cooling PL CondB</b>                                                                    |       |           |
| Pc @ 30°C (Declared Cooling Capacity @ 30°C)                                               | 1.92  | kW        |
| EER @ 30°C (Declared Energy Efficiency @ 30°C )                                            | 6.6   |           |
| <b>Cooling PL CondC</b>                                                                    |       |           |
| Pc @ 25°C (Declared Cooling Capacity @ 25°C)                                               | 1.23  | kW        |
| EER @ 25°C (Declared Energy Efficiency @ 25°C)                                             | 10.9  |           |
| <b>Cooling PL CondD</b>                                                                    |       |           |
| Pc @ 20°C (Declared Cooling Capacity @ 20°C)                                               | 0.94  | kW        |
| EER @ 20°C (Declared Energy Efficiency @ 20°C )                                            | 15.6  |           |
| <b>Standard Heating</b>                                                                    |       |           |
| Ph (Heating Capacity)                                                                      | 3.2   | kW        |
| Peh (Net Electric Power Consumption for Heating Only application )                         | 0.8   | kW        |
| COP (Coefficient Of Performance)                                                           | 4     |           |



### Certificate N° 21.03.105

This document is valid at the date of issue - Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)

Ce document est valide à la date d'édition - Vérifiez la date de validité sur [www.eurovent-certification.com](http://www.eurovent-certification.com)

| Heating PL CondA                                                                       |      |           |
|----------------------------------------------------------------------------------------|------|-----------|
| Ph @ -7°C (Declared Heating Capacity @ -7°C)                                           | 2.12 | kW        |
| COP @ -7°C (Declared Coefficient Of Performances @ -7°C)                               | 2.9  |           |
| Heating PL CondB                                                                       |      |           |
| Ph @ +2°C (Declared Heating Capacity @ +2°C)                                           | 1.29 | kW        |
| COP @ 2°C (Declared Coefficient Of Performances @ 2°C)                                 | 4.76 |           |
| Heating PL CondC                                                                       |      |           |
| Ph @ +7°C (Declared Heating Capacity @ +7°C)                                           | 1.05 | kW        |
| COP @ +7°C (Declared Coefficient Of Performances @ +7°C)                               | 5.98 |           |
| Heating PL CondD                                                                       |      |           |
| Ph @ +12°C (Declared Heating Capacity @ +12°C)                                         | 0.9  | kW        |
| COP @ +12°C (Declared Coefficient Of Performances @ +12°C)                             | 7.01 |           |
| Bivalent Point                                                                         |      |           |
| Tbiv (Bivalent Temperature)                                                            | -7   | °C        |
| COP @ Tbiv (Declared coefficient of performances at bivalent temperature condition)    | 2.9  |           |
| Ph TBiv (Heating capacity at bivalent temperature)                                     | 2.12 | kW        |
| TOL Runing Test                                                                        |      |           |
| TOL (Operating LimitTemperature )                                                      | -10  | °C        |
| Ph E (Declared Heating Capacity @ TOL)                                                 | 2.05 | kW        |
| COP E (Declared Coefficient Of Performances @ TOL)                                     | 2.8  |           |
| Heating Warmer Climate                                                                 |      |           |
| SCOP (Refrence SCOP Warmer Climate)                                                    | 5.1  |           |
| SCOP Class warmer climate (Seasonal Coefficient Of Performance Class (warmer climate)) | A+++ |           |
| Qhe (Annual Electricity consumption)                                                   | 631  | kWh/annum |
| Poffc                                                                                  |      |           |
| Poff (Power consumption in off mode)                                                   | 2    | W         |
| Psb                                                                                    |      |           |
| Psb (Power consumption in standby mode cooling (Paux, cooling))                        | 2    | W         |
| Ptoc                                                                                   |      |           |
| Pto (Power consumption in thermostat off mode)                                         | 10   | W         |
| General                                                                                |      |           |

# PRODUCT PERFORMANCE RATING

Document ID 1662723918-5a-6ffe879d

Issued on: 9 September 2022 - Délivré le : 9 septembre 2022

This product is certified by Eurovent Certita Certification as mentioned on:

Ce produit est certifié par Eurovent Certita Certification comme mentionné sur :



## Certificate N° 21.03.105

This document is valid at the date of issue - Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)

Ce document est valide à la date d'édition - Vérifiez la date de validité sur [www.eurovent-certification.com](http://www.eurovent-certification.com)

| FEATURE                                                                                                      | VALUE        | UNIT |
|--------------------------------------------------------------------------------------------------------------|--------------|------|
| General                                                                                                      |              |      |
| Inverter (Inverter (True/False))                                                                             | true         |      |
| Capacity Control                                                                                             | Variable     |      |
| Main Power Supply (Voltage (V) - Phase - Frequency (Hz))                                                     | 230-1-50     |      |
| Refrigerant                                                                                                  | R32          |      |
| Refr. Line (Refrigerant Line. If possible )                                                                  | 5m           | m    |
| Mounting (Mounting Type)                                                                                     | Wall mounted |      |
| Eligible CEE                                                                                                 |              |      |
| Eligible CEE (this item provide information if the unit is eligible to the certificat d'economie d'energie ) | true         |      |

**Air Conditioners / Climatiseurs**  
**/ Comfort Air Conditioners below 12kW**  
**/ Climatiseurs de moins de 12kW**

Granted on March 31, 2021 – Date 1ère admission 31 mars 2021

This document is valid at the date of issue – Check the current validity on:  
*Document valable à la date d'émission – Vérifier la validité en cours sur :*  
[www.eurovent-certification.com](http://www.eurovent-certification.com)

**Participant/Titulaire**

Thermor  
ZA Charles Beauhaire – 17 rue Croix Fauchet – BP46  
45141 Saint Jean de la ruelle, France

This product performance certificate is issued by Eurovent Certita Certification according to the certification rules:

**ECP AC – « Air Conditioners » in force at established date.**

Pursuant to the decision notified by Eurovent Certita Certification, the right to use the mark ECP shall be granted to the beneficiary company for all products inside the defined scope according to “certify-all” principle and in the conditions defined by the certification program mentioned.

Unless withdrawn or suspended, this certificate remains valid as long as the requirements for the certification program framework are met. The validity of the certificate is to be verified on [www.eurovent-certification.com](http://www.eurovent-certification.com)

THIS CERTIFICATE HAS BEEN ISSUED ON 12/10/2021  
THIS CERTIFICATE IS VALID UNTIL 31/10/2022

*Ce certificat de performance produit est délivré par Eurovent Certita Certification dans les conditions fixées par le référentiel :*

**ECP AC – « Climatiseurs » en vigueur à date d'édition.**


*En vertu de la décision notifiée par Eurovent Certita Certification, le droit d'usage de la marque ECP, est accordé à la société qui en est bénéficiaire pour les tous les produits entrant dans le champ d'application défini selon le principe “certify-all” et dans les conditions définies par le programme de certification mentionné.*

*Sauf retrait ou suspension, ce certificat demeure valide tant que les conditions du référentiel du programme de certification sont respectées. La validité du certificat est à vérifier sur le site Internet [www.eurovent-certification.com](http://www.eurovent-certification.com)*

CE CERTIFICAT A ÉTÉ EMIS LE 12/10/2021  
CE CERTIFICAT EST VALIDE JUSQU'AU 31/10/2022

Paris, 12 octobre 2021

MANAGING BOARD MEMBER / MEMBRE DIRECTOIRE



Organisme accrédité n° 5-0517 Certification  
Produits et Services selon la norme NF EN  
ISO/CEI 17065:2012  
Portée disponible sur [www.cofrac.fr](http://www.cofrac.fr)

Accreditation #5-0517 Products and Services  
Certification according to NF EN ISO/CEI  
17065:2012 –  
Scope available on [www.cofrac.fr](http://www.cofrac.fr)

COFRAC est signataire des accords MLA d'EA  
et MLA d'IAF,  
COFRAC is signatory of EA MLA and IAF MLA,  
list of EA members is available on  
[www.european-accreditation.org/ea-members](http://www.european-accreditation.org/ea-members)  
list of IAF members is available on  
[www.iaf.nu/articles/IAF\\_MEMBERS\\_SIGNATORIES/4](http://www.iaf.nu/articles/IAF_MEMBERS_SIGNATORIES/4)

## Appendix / Annexe

Granted on March 31, 2021 – *Date 1ère admission 31 mars 2021*

This document is valid at the date of issue – Check the current validity on:

*Document valable à la date d'émission – Vérifier la validité en cours sur :*

[www.eurovent-certification.com](http://www.eurovent-certification.com)

List of certified products and characteristics is displayed on:

*La liste des références et caractéristiques certifiées est disponible sur le site :*

[www.eurovent-certification.com](http://www.eurovent-certification.com)

This product performance certificate is valid for the following trade names:

*Ce certificat de performance produit est valide pour les marques commerciales suivantes:*

Trade Name / Marque Commerciale

THERMOR

This product performance certificate is valid for the following manufacturing places:

*Ce certificat de performance produit est valide pour les sites de production suivants:*

Manufacturing Place / Site de Production

Not applicable for this certification programme / Non applicable pour ce programme de certification

This product performance certificate is valid for the following software:

*Ce certificat de performance produit est valide pour les logiciels de sélection suivants:*

Software / Logiciel de sélection

Not applicable for this certification programme / Non applicable pour ce programme de certification