

Information sheet (Lot.10)

This information includes the results of calculation of the seasonal energy consumption and efficiency for air conditioner in regards to ErP pursuant to the Commission Regulation(EU) No.206/2012 and No.626/2011.

Information to identify the mode(s) to which the information relates to:

AIR CONDITIONER
 TYPE : MULTI SPLIT
 WALL MOUNTED
 Indoor unit(s) : ASHG07KMCE x 4
 Outdoor unit : AOHG30KBTA4
 BRAND : GENERAL

N/A = Not Applicable

Function			
Cooling	Yes	Average	Yes
Heating	Yes	Warmer	No
		Colder	No

Design load				Seasonal efficiency			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Cooling	Pdesignc	8.0	kW	Cooling	SEER	8.50	-
Heating/Average	Pdesignh	6.5	kW	Heating/Average	SCOP/A	4.60	-
Heating/Warmer	Pdesignh	N/A	kW	Heating/Warmer	SCOP/W	N/A	-
Heating/Colder	Pdesignh	N/A	kW	Heating/Colder	SCOP/C	N/A	-

Cooling							
Declared capacity for cooling, at indoor temperature 27 (19) °C and outdoor temperature Tj				Declared energy efficiency ratio, at indoor temperature 27 (19) °C and outdoor temperature Tj			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Tj = 35°C	Pdc	8.00	kW	Tj = 35°C	EER d	3.90	-
Tj = 30°C	Pdc	5.89	kW	Tj = 30°C	EER d	5.59	-
Tj = 25°C	Pdc	3.79	kW	Tj = 25°C	EER d	10.59	-
Tj = 20°C	Pdc	2.11	kW	Tj = 20°C	EER d	17.84	-

Heating/Average							
Declared capacity for heating/Average season, at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance/Average season, at indoor temperature 20 °C and outdoor temperature Tj			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Tj = -7°C	Pdh	5.75	kW	Tj = -7°C	COPd	3.06	-
Tj = 2°C	Pdh	3.50	kW	Tj = 2°C	COPd	4.70	-
Tj = 7°C	Pdh	3.79	kW	Tj = 7°C	COPd	6.04	-
Tj = 12°C	Pdh	3.70	kW	Tj = 12°C	COPd	7.84	-
Tj = bivalent temperature	Pdh	5.75	kW	Tj = bivalent temperature	COPd	3.06	-
Tj = operating limit	Pdh	5.10	kW	Tj = operating limit	COPd	2.72	-

Heating/Warmer							
Declared capacity for heating/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Tj = 2°C	Pdh	N/A	kW	Tj = 2°C	COPd	N/A	-
Tj = 7°C	Pdh	N/A	kW	Tj = 7°C	COPd	N/A	-
Tj = 12°C	Pdh	N/A	kW	Tj = 12°C	COPd	N/A	-
Tj = bivalent temperature	Pdh	N/A	kW	Tj = bivalent temperature	COPd	N/A	-
Tj = operating limit	Pdh	N/A	kW	Tj = operating limit	COPd	N/A	-

Heating/Colder							
Declared capacity for heating/Colder season, at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance/Colder season, at indoor temperature 20 °C and outdoor temperature Tj			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Tj = -7°C	Pdh	N/A	kW	Tj = -7°C	COPd	N/A	-
Tj = 2°C	Pdh	N/A	kW	Tj = 2°C	COPd	N/A	-
Tj = 7°C	Pdh	N/A	kW	Tj = 7°C	COP d	N/A	-
Tj = 12°C	Pdh	N/A	kW	Tj = 12°C	COP d	N/A	-
Tj = bivalent temperature	Pdh	N/A	kW	Tj = bivalent temperature	COP d	N/A	-
Tj = operating limit	Pdh	N/A	kW	Tj = operating limit	COP d	N/A	-
Tj=-15°C	Pdh	N/A	kW	Tj = -15°C	COP d	N/A	-

Bivalent temperature				Operating limit temperature			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Heating/Average	T _{biv}	-7	°C	Heating/Average	T _{ol}	-15	°C
Heating/Warmer	T _{biv}	N/A	°C	Heating/Warmer	T _{ol}	N/A	°C
Heating/Colder	T _{biv}	N/A	°C	Heating/Colder	T _{ol}	N/A	°C

Cycling interval capacity				Cycling interval efficiency			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
For cooling	P _{cycc}	N/A	kW	For cooling	EER _{cycc}	N/A	-
For heating	P _{cycc}	N/A	kW	For heating	COP _{cycc}	N/A	-
Degradation coefficient cooling	C _{dc}	0.25	-	Degradation coefficient heating	C _{dh}	0.25	-

Electric power input in power modes other than 'active mode'				Annual electricity consumption			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Off mode (Cooling/Heating)	P _{OFF}	4.0/4.0	W	Cooling	Q _{CE}	329	kWh/a
Standby mode (Cooling/Heating)	P _{SB}	4.0/4.0	W	Heating/Average	Q _{HE}	1978	kWh/a
Thermostat-off mode (Cooling/Heating)	P _{TO}	10.0/20.0	W	Heating/Warmer	Q _{HE}	N/A	kWh/a
Crankcase heater mode (Cooling/Heating)	P _{CK}	0.0/0.0	W	Heating/Colder	Q _{HE}	N/A	kWh/a

Capacity control			Other items			
Item		Y/N	Item	Symbol	Value	Unit
Fixed		No	Sound power level (Indoor/Outdoor)	L _{WA}	54.0/63.0	dB(A)
Staged		No	Global warming potential	GWP	675	kgCO ₂ eq.
Variable		Yes	Rated air flow (Indoor/Outdoor)	-	650/2400	m ³ /h

Contact details for obtaining more information	FUJITSU GENERAL LIMITED 3-3-17, Suenaga, Takatsu-ku, Kawasaki, 213-8502, Japan
--	---

V20121214

Information of indoor unit combination

Indoor unit combination (all indoor unit WALL MOUNTED type only)

N/A = Not Applicable

Combination of Indoor unit *1				Cooling				Heating/Average				Heating/Warmer				Heating/Colder			
room1	room2	room3	room4	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class
				Pdesigngc kW	SEER	Q _{CE} kWh/a	-	Pdesigngh kW	SCOP/A	Q _{HE} kWh/a	-	Pdesigngn kW	SCOP/W	Q _{HE} kWh/a	-	Pdesigngc kW	SCOP/C	Q _{HE} kWh/a	-
07	22	-	-	8.0	7.5	373	A++	6.5	4.1	2216	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	24	-	-	8.0	7.5	373	A++	6.5	4.1	2216	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	22	-	-	8.0	7.5	373	A++	6.5	4.1	2216	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	24	-	-	8.0	7.5	373	A++	6.5	4.1	2216	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	18	-	-	8.0	7.5	373	A++	6.5	4.1	2216	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	22	-	-	8.0	7.5	373	A++	6.5	4.1	2216	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	24	-	-	8.0	7.5	373	A++	6.5	4.1	2216	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	18	-	-	8.0	7.5	373	A++	6.5	4.1	2216	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	22	-	-	8.0	7.5	373	A++	6.5	4.1	2216	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	24	-	-	8.0	7.5	373	A++	6.5	4.1	2216	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18	18	-	-	8.0	7.5	373	A++	6.5	4.1	2216	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18	22	-	-	8.0	7.5	373	A++	6.5	4.1	2216	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18	24	-	-	8.0	7.5	373	A++	6.5	4.1	2216	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
22	22	-	-	8.0	7.5	373	A++	6.5	4.1	2216	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
22	24	-	-	8.0	7.5	373	A++	6.5	4.1	2216	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
24	24	-	-	8.0	7.5	373	A++	6.5	4.1	2216	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	-	7.5	8.1	324	A++	6.0	4.4	1909	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	18	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	22	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	24	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	-	7.0	8.2	299	A++	6.0	4.4	1909	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	18	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	22	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	24	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	12	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	14	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	18	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	22	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	24	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	14	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	18	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	22	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	24	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	18	18	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	18	22	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	18	24	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	-	7.5	8.1	324	A++	6.0	4.4	1909	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	14	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	18	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	22	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	24	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

*1

07 = 7000Btu/h class = 2.0kW class

09 = 9000Btu/h class = 2.5kW class

12 = 12000Btu/h class = 3.5kW class

14 = 14000Btu/h class = 4.0kW class

18 = 18000Btu/h class = 5.0kW class

22 = 22000Btu/h class = 6.0kW class

24 = 24000Btu/h class = 7.0kW class

Indoor unit combination (all indoor unit WALL MOUNTED type only)

N/A = Not Applicable

Combination of Indoor unit *1				Cooling				Heating/Average				Heating/Warmer				Heating/Colder			
room1	room2	room3	room4	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class
				Pdesignhc	SEER	Q _{CE}	-	Pdesigngh	SCOP/A	Q _{HE}	-	Pdesigngh	SCOP/W	Q _{HE}	-	Pdesigngh	SCOP/C	Q _{HE}	-
				kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-
09	12	12	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	14	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	18	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	22	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	24	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	14	14	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	14	18	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	14	22	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	14	24	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	12	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	14	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	18	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	22	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	24	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	14	14	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	14	18	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	18	18	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	14	14	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	14	18	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	09	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	12	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	14	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	18	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	09	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	12	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	14	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	18	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	12	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	14	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	18	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	14	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	18	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	09	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	12	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	14	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	18	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	12	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	14	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	18	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	14	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	18	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

*1
 07 = 7000Btu/h class = 2.0kW class
 09 = 9000Btu/h class = 2.5kW class
 12 = 12000Btu/h class = 3.5kW class
 14 = 14000Btu/h class = 4.0kW class
 18 = 18000Btu/h class = 5.0kW class
 22 = 22000Btu/h class = 6.0kW class
 24 = 24000Btu/h class = 7.0kW class

Indoor unit combination (all indoor unit WALL MOUNTED type only)

N/A = Not Applicable

Combination of Indoor unit *1				Cooling				Heating/Average				Heating/Warmer				Heating/Colder			
room1	room2	room3	room4	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class
				Pdesignc	SEER	Q _{CE}		Pdesignh	SCOP/A	Q _{HE}		Pdesignh	SCOP/W	Q _{HE}		Pdesignh	SCOP/C	Q _{HE}	
				kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-
07	12	12	12	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	12	14	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	12	18	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	14	14	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	09	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	12	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	14	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	18	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	12	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	14	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	18	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	14	14	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	12	12	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	12	14	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	14	14	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	12	12	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

*1

- 07 = 7000Btu/h class = 2.0kW class
- 09 = 9000Btu/h class = 2.5kW class
- 12 = 12000Btu/h class = 3.5kW class
- 14 = 14000Btu/h class = 4.0kW class
- 18 = 18000Btu/h class = 5.0kW class
- 22 = 22000Btu/h class = 6.0kW class
- 24 = 24000Btu/h class = 7.0kW class

Indoor unit combination (except all indoor unit WALL MOUNTED type)

N/A = Not Applicable

Combination of Indoor unit *1				Cooling				Heating/Average				Heating/Warmer				Heating/Colder			
room1	room2	room3	room4	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class
				Pdesigngn	SEER	Q _{CE}	-	Pdesigngh	SCOP/A	Q _{HE}	-	Pdesigngn	SCOP/W	Q _{HE}	-	Pdesigngn	SCOP/C	Q _{HE}	-
				kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-
07	22	-	-	8.0	5.9	475	A+	6.5	3.9	2333	A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	24	-	-	8.0	5.9	475	A+	6.5	3.9	2333	A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	22	-	-	8.0	5.9	475	A+	6.5	3.9	2333	A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	24	-	-	8.0	5.9	475	A+	6.5	3.9	2333	A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	18	-	-	8.0	5.9	475	A+	6.5	3.9	2333	A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	22	-	-	8.0	5.9	475	A+	6.5	3.9	2333	A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	24	-	-	8.0	5.9	475	A+	6.5	3.9	2333	A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	18	-	-	8.0	5.9	475	A+	6.5	3.9	2333	A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	22	-	-	8.0	5.9	475	A+	6.5	3.9	2333	A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	24	-	-	8.0	5.9	475	A+	6.5	3.9	2333	A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18	18	-	-	8.0	5.9	475	A+	6.5	3.9	2333	A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18	22	-	-	8.0	5.9	475	A+	6.5	3.9	2333	A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18	24	-	-	8.0	5.9	475	A+	6.5	3.9	2333	A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
22	22	-	-	8.0	5.9	475	A+	6.5	3.9	2333	A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
22	24	-	-	8.0	5.9	475	A+	6.5	3.9	2333	A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
24	24	-	-	8.0	5.9	475	A+	6.5	3.9	2333	A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	-	7.5	6.4	410	A++	6.0	4.1	2049	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	18	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	22	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	24	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	-	7.0	6.5	377	A++	6.0	4.1	2049	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	18	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	22	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	24	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	12	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	14	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	18	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	22	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	24	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	14	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	18	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	22	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	24	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	18	18	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	18	22	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	18	24	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	-	7.5	6.4	410	A++	6.0	4.1	2049	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	14	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	18	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	22	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	24	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

*1

07 = 7000Btu/h class = 2.0kW class

09 = 9000Btu/h class = 2.5kW class

12 = 12000Btu/h class = 3.5kW class

14 = 14000Btu/h class = 4.0kW class

18 = 18000Btu/h class = 5.0kW class

22 = 22000Btu/h class = 6.0kW class

24 = 24000Btu/h class = 7.0kW class

Indoor unit combination (except all indoor unit WALL MOUNTED type)

N/A = Not Applicable

Combination of Indoor unit *1				Cooling				Heating/Average				Heating/Warmer				Heating/Colder			
room1	room2	room3	room4	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class
				Pdesignh	SEER	Q _{CE}	-	Pdesignh	SCOP/A	Q _{HE}	-	Pdesignh	SCOP/W	Q _{HE}	-	Pdesignh	SCOP/C	Q _{HE}	-
				kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-
09	12	12	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	14	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	18	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	22	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	24	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	14	14	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	14	18	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	14	22	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	14	24	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	12	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	14	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	18	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	22	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	24	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	14	14	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	14	18	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	18	18	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	14	14	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	14	18	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	09	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	12	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	14	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	18	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	09	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	12	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	14	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	18	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	12	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	14	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	18	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	14	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	18	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	09	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	12	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	14	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	18	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	12	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	14	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	18	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	14	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	18	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

*1
 07 = 7000Btu/h class = 2.0kW class
 09 = 9000Btu/h class = 2.5kW class
 12 = 12000Btu/h class = 3.5kW class
 14 = 14000Btu/h class = 4.0kW class
 18 = 18000Btu/h class = 5.0kW class
 22 = 22000Btu/h class = 6.0kW class
 24 = 24000Btu/h class = 7.0kW class

Indoor unit combination (except all indoor unit WALL MOUNTED type)

N/A = Not Applicable

Combination of Indoor unit *1				Cooling				Heating/Average				Heating/Warmer				Heating/Colder			
room1	room2	room3	room4	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class
				Pdesignc	SEER	Q _{CE}	-	Pdesignh	SCOP/A	Q _{HE}	-	Pdesignh	SCOP/W	Q _{HE}	-	Pdesignh	SCOP/C	Q _{HE}	-
				kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-
07	12	12	12	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	12	14	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	12	18	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	14	14	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	09	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	12	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	14	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	18	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	12	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	14	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	18	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	14	14	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	12	12	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	12	14	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	14	14	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	12	12	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

*1

- 07 = 7000Btu/h class = 2.0kW class
- 09 = 9000Btu/h class = 2.5kW class
- 12 = 12000Btu/h class = 3.5kW class
- 14 = 14000Btu/h class = 4.0kW class
- 18 = 18000Btu/h class = 5.0kW class
- 22 = 22000Btu/h class = 6.0kW class
- 24 = 24000Btu/h class = 7.0kW class

Information of unit specification

Model Type	Model No.	Capacity Class	Dimension [H x W x D]	Sound power level(Cooling)	Sound power level(Heating)	
		kW	mm	dB(A)	dB(A)	
OUTDOOR	AOHG30KBTA4	-	884 x 820 x 315	63	66	
WALL MOUNTED	ASHG07KMCC ASHG07KMCE ASHG07KMCF	2.0	270 x 834 x 215	54	56	
	ASHG09KMCC ASHG09KMCE ASHG09KMCF	2.5		55	57	
	ASHG12KMCC ASHG12KMCE ASHG12KMCF	3.5		55	58	
	ASHG14KMCC ASHG14KMCE ASHG14KMCF	4.0		57	59	
	ASHG07KGTB ASHG07KGTE ASHG07KGTF	2.0	270 x 834 x 215	54	56	
	ASHG09KGTB ASHG09KGTE ASHG09KGTF	2.5		55	57	
	ASHG12KGTB ASHG12KGTE ASHG12KGTF	3.5		56	58	
	ASHG14KGTB ASHG14KGTE ASHG14KGTF	4.0		57	59	
	ASHG07KMTB	2.0	270 x 834 x 215	54	56	
	ASHG09KMTB	2.5		55	57	
	ASHG12KMTB	3.5		55	58	
	ASHG14KMTB	4.0		57	59	
	ASHG18KMTB ASHG18KMTE	5.0	280 x 980 x 240	60	61	
	ASHG22KMTB ASHG22KMTE	6.0		62	62	
	ASHG24KMTB ASHG24KMTE	7.0		65	65	
	ASHG07KETA ASHG07KETE ASHG07KETF	2.0	295 x 950 x 230	54	56	
	ASHG09KETA ASHG09KETE ASHG09KETF	2.5		55	57	
	ASHG12KETA ASHG12KETE ASHG12KETF	3.5		55	58	
	ASHG14KETA ASHG14KETE ASHG14KETF	4.0		57	59	
	ASHG07KETA-B ASHG07KETE-B ASHG07KETF-B	2.0	295 x 950 x 230	54	56	
	ASHG09KETA-B ASHG09KETE-B ASHG09KETF-B	2.5		55	57	
	ASHG12KETA-B ASHG12KETE-B ASHG12KETF-B	3.5		55	58	
	ASHG14KETA-B ASHG14KETE-B ASHG14KETF-B	4.0		57	59	
	CASSETTE	AUXG07KVLA	2.0	245 x 570 x 570 (Panel: 49 x 620 x 620)	46	47
		AUXG09KVLA	2.5		46	47
		AUXG12KVLA	3.5		49	49
		AUXG14KVLA	4.0		50	55
		AUXG18KVLA	5.0		50	55
AUXG22KVLA		6.0	56		57	
DUCT	ARXG07KSLAP	2.0	198 x 700 x 450	52	53	
	ARXG09KSLAP	2.5		54	56	
	ARXG12KSLAP	3.5		55	57	
	ARXG14KSLAP	4.0		60	62	
	ARXG18KSLAP	5.0	198 x 900 x 450	58	59	
	ARXG07KLLAP	2.0	198 x 700 x 620	57	57	
	ARXG09KLLAP	2.5		57	57	
	ARXG12KLLAP	3.5		58	58	
	ARXG14KLLAP	4.0		60	60	
	ARXG18KLLAP	5.0	198 x 900 x 620	58	58	
	ARXG22KMLB	6.0	270 x 1135 x 700	60	62	
	ARXH22KMTAP	6.0	240 x 1000 x 700	58	58	
FLOOR	AGHG09KVCA	2.5	600 x 740 x 200	52	52	
	AGHG12KVCA	3.5		55	55	
	AGHG14KVCA	4.0		56	56	
CEILING	ABHG18KRTA	5.0	235 x 1080 x 705	53	53	
	ABHG22KRTA	6.0		57	57	